



Certificate of Compliance

Certificate Number: LR 28549-59

Revision: LR 28549-89

Date Issued: June 24, 1996

Issued To: Moore Industries - International, Inc.
16650 Schoenborn Street
Sepulveda, CA 91343
USA

The products listed below are eligible to bear the CSA Mark.

Issued By: John Chiang, P. Eng.
Vancouver, BC Canada

Signature

CLASS

2252 01 - PROCESS CONTROL EQUIPMENT

PRODUCTS

Field configurable signal converter/isolator, Model FCT, rated 22-300 V dc, 90-260 V ac, 3.5 W nominal, 5 W max.

Note: This equipment is Certified for use in other equipment where the suitability of the combination is to be determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No 142-M1987 - Process Control Equipment - Industrial Products