



Certificate of Compliance

Certificate Number: LR 28549-87

Revision: LR 28549-87

Date Issued: May 20th, 1996

Issued To: Moore Industries - International Inc.
16650 Schoenborn St.
Sepulveda, CA 91343

The Products listed below are eligible to bear the CSA Mark.

The "NRTL/C" indicator appears adjacent to the CSA Mark.

Issued By: Dan Livermore, C.E.T
Edmonton, AB CANADA

Signature 

CLASS

2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations
2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

PRODUCTS

Class I, Division 2, Groups A, B, C and D; Encl Type 3R:

Current-to-pneumatic pressure transmitters, Model IPF-XXXX, suffixes denoting signal input range, pressure output range, and other optional mechanical features. Rated input 4-20 mA (or 10-50 mA), 42 V dc max; output 186 kpa (27 psig) max.



Certificate of Compliance

Certificate Number: LR 28549-87

Revision: LR 28549-87

Date Issued: May 20th, 1996

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No 0-M1991	-	General Requirements, Canadian Electrical Code, Part II.
0.5-198	-	Threaded Conduit Entries.
94-M91	-	Special Purpose Enclosures 2, 3, 4 and 5.
142-M1987	-	Process Control Equipment.
213-M1987	-	Electrical Equipment for use in Class I, Division 2 Hazardous Locations.
ANSI/UL Std.	UL 508	- Industrial Control Equipment.
	UL 1092	- Process Control Equipment.
	UL 1604	- Electrical Equipment for use in Class I and II, Division 2 Hazardous (Classified) Locations.

MARKINGS

Following data appears on a 0.010-in thick stainless steel nameplate, secured in place by pop-rivets:

- Name of Manufacturer, or trademark, or CSA File No "LR 28549", adjacent to the CSA Monogram;
- Catalogue number;
- Month and year of manufacture, or date code, or serial number
- electrical input ratings;
- hazardous location ratings, (i.e., Class, Division and Groups);
- Special Purpose Enclosure designation (Encl Type 3R);
- Pressure ratings (in kPa);
- Cautionary statements;
- WARNING: Do not disconnect while circuit is live, unless area is known to be non-hazardous; and,
The equivalent french translation (Optional).
- The CSA Monogram, or the CSA Monogram with the "NRTL" or "NRTL/C" indicator.

FACTORY TESTS

None Required



Supplement to Certificate of Compliance

Certificate Number: LR 28549-87

Product Certification History

Revision	Date	Description
LR 28549-87	96/05/20	Original Certification [Certificate of Compliance Issued].

The products listed, including the latest revision described above, are eligible to be marked in accordance with the referenced Certificate.

Signature

Dan Livermore, C.E.T.
Edmonton, AB CANADA