

1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

IPH/a/b/c/d [e]. Current-to-Pressure (I/P) Transmitter.

IS/I,II,III/1/ABCDEFG/T6 Ta=60°C; - 100-100-53/A; Entity; NI/II/2/ABCD/T6 Ta=60°C;

S/II,III/FG/T6 Ta=60°C; Type 4X; IP65

Entity Parameters:

Vmax = 30V, Imax = 85mA, C_i = 0, L_i = 5mH

a = Input 4-20mA.

b = Output 3-15psig, 3-27psig, 15-3psig, 20-100KPa, 0.2-1Bar or 0.2-1Kg/cm².

c = Supply pressure 20psi, 35psi, 140KPa, 1.4Bar or 1.4Kg/cm².

d = Blank (Nonincendive) or -ISF (Intrinsically safe & Nonincendive)

e = Housings WDNA, WDMA, WDNS or WDMS.

Equipment Ratings:

Intrinsically Safe (Entity) for use in Class I, II, III, Division 1, Groups A, B, C, D, E, F and G; in accordance with Document No.100-100-53; Nonincendive for use in Class I, Division 2, Groups A, B, C and D; Suitable for use in Class II, III, Division 2, Groups F and G; indoor and outdoor NEMA, Type 4X; IP65 Hazardous (Classified) Locations.

Approved for:

Moore Industries International
Sepulveda, CA 91343 USA

This certifies that the equipment described has been found to comply with the following Factory Mutual Research Approval Standards and other documents:

Class 3600	1998
Class 3610	1988
Class 3611	1986
Class 3810	1989
ANSI/NEMA 250	1991


Original Approval Job Identification: 3002393 Approval Granted: July 6, 1999

Subsequent Revision Reports / Date Approval Amended

Factory Mutual Research Corporation



Robert L. Martell, Jr.
Assistant Vice President
Approvals Division


Date