



# Certificate of Compliance

**Certificate Number:** LR 28549-67

**Revision:** LR 28549-91

**Date Issued:** March 11, 1997

**Issued To:** Moore Industries International Inc.  
16650 Schoenborn Street  
Sepulveda, CA 91343-6196

**The products listed below are eligible to bear the CSA Mark.**

**Note:** The "NRTL/C" indicator appears adjacent to the CSA Mark.

**Issued By:** John Chiang, P. Eng.  
Vancouver, BC Canada

**Signature**

## **PRODUCTS**

Isolating Signal Transmitter, Model IST, rated 117 V ac, 117/230 V ac (jumper selectable), or 117/240 V ac (jumper selectable), or 24 V dc, 5 W max.

## **APPLICABLE REQUIREMENTS**

- |                            |   |   |
|----------------------------|---|---|
| CAN/CSA-C22.2 No 142-M1987 | - | Process Control Equipment   |
| UL 1092                    | - | Process Control Equipment   |
| UL 840                     | - | Insulation Coordination Including Creepage and Clearance Distances for Electrical Equipment |