



# Certificate of Compliance

Certificate: 1837107 (LR 28549)

Master Contract: 152564

Project: 1837107


Date Issued: 2007-01-10

Issued to: **Moore Industries - International,  
Inc.  
16650 Schoenborn St  
Sepulveda, CA 91343-6196  
USA  
Attention: Gus Elias**


*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'*



Issued by:

  
Andrea Holbeche

Authorized by: Patricia Pasemko, Operations  
Manager



## PRODUCTS

**CLASS 4418 82** - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations -  
Certified to US Standards

**CLASS 4418 02** - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations

Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III; Type 4X, IP66

Explosion-proof enclosures. Series "SB" Instrument Housing, cast 316 stainless steel, with glass or solid cover, three 1/2" or 3/4" NPT conduit entries. Optional 2" stainless steel pipe-mount hardware kit P.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



**Certificate:** 1837107 (LR 28549)

**Master Contract:** 152564

**Project:** 1837107

**Date Issued:** 2007/01/10

---

**APPLICABLE REQUIREMENTS**

C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CAN/CSA-C22.2 No. 94-M91- Special Purpose Enclosures

FM 3600 - 1998 -Electrical Equipment for Use in Hazardous (Classified) Locations. General Requirements.

FM 3615 - 1989 - Explosion-proof Electrical Equipment

ANSI/NEMA 250 - 1991 - Enclosures for Electrical Equipment

CAN/CSA-C22.2 No. 60529:05 - Degrees of protection provided by enclosures (IP Code)



## *Supplement to Certificate of Compliance*

Certificate: 1837107

Master Contract: 152564

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
1837107	2007/01/10	C_US approval - acceptance of FM report for empty SS, Series "SB" housing.