

1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

Model/Input/Output/Power/-Options [LH2abc]. Two-Wire Transmitters.

SIY/PRG/4-20MA/10-42DC/-ISA, ISC, ISCN, ISE, ISF, NE [LH2abc]

T2X/PRG/4-20MA/8-42DC/-ISA, ISC, ISCN, ISE, ISF, NE [LH2abc]

THZ/PRG/4-20MA/12-42DC/-ISA, ISC, ISCN, ISE, NE [LH2abc]

TRX/PRG/4-20MA/8-42VDC/-ISA, ISC, ISCN, ISE, ISF, NE [LH2abc]

TRY/PRG/4-20MA/10-42VDC/-ISA, ISC, ISCN, ISE, ISF, NE [LH2abc]

a = Type of conduit entry/connection **M** (Metric M20 x 1.5) or **N** (1/2" NPT).

b = Standard black aluminum cover **S**.

c = Optional 2" stainless steel pipe-mount hardware kit **P**.

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups A, B, C and D; Dust-Ignitionproof for Class II/III, Division 1 Groups E, F, and G, hazardous (classified) locations, indoors and outdoors rated NEMA Type 4X and IP66.

Approved for:

Moore Industries-International, Inc.
16650 Schoenborn Street
Sepulveda, CA 91343-6196

This certifies that the equipment described has been found to comply with the following Factory Mutual Research Approval Standards and other documents:

Class 3600	1998
Class 3615	1989
Class 3810	1989
(Includes Supplement 1)	1995
ANSI/NEMA-250	1991
IEC-529	1989

Original Approval Job Identification: 3000690 Approval Granted: November 12, 1998

Subsequent Revision Reports / Date Approval Amended

3007951

June 5, 2000

Factory Mutual Research Corporation



Roger P. Lutfy, Electrical Section Manager
Approvals Division

7/27/00
Date