

Certificate of Compliance

Certificate: 1361000 (LR 28549)

Master Contract: 152564

Project: 1361000 (Edition 1)


Date Issued: March 20, 2003

Issued to: Moore Industries - International,
16650 Schoenborn Street
Sepulveda, CA
USA

*The products listed below are eligible to bear the CSA Mark shown
with adjacent indicators 'C' and 'US'*



Issued by: 
Patrick Conway C.E.T.
Certification Specialist

Authorized by: 
Terry Nagy
Operations Manager

PRODUCTS

CLASS 2258-04 PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For Hazardous Locations

Class I, Division 1, Groups A, B, C and D

CLASS 2258-84 PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For Hazardous Locations -
Certified to US Standards

Class I, Zone 0, AEx ia IIC T5/T6

Programmable Loop Display models SPD and SPD-BL. Intrinsically Safe when installed as per Moore Industries
Field Installation Drawing 100-100-66. Temperature Code T6 @ 60°C, T5 @ 85°C; Ambient Temperature
Range: -40°C to 85°C. Enclosure Type 4X & IP66

Entity Parameters:

V_{max} = 30Vdc I_{max} = 110mA P_{max} = 550mW C_i = 0ηF L_i = 0μH



CSA INTERNATIONAL

Certificate: 1361000

Project: 1361000

Master Contract: 152564

Date: March 20, 2003

CLASS 2258-02 PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258-82 PROCESS CONTROL EQUIPMENT - For Hazardous Locations - Certified to US Standards

Class II, Division 1, Groups E, F, and G; Class II, Division 2, Groups F and G; Class I, Division 2, Groups A, B, C, and D; Class III, Divisions 1 & 2

Programmable Loop Display models SPD and SPD-BL. Rated at 30Vdc, 110mA, 550mW. Temperature Code T6 @ 60°C, T5 @ 85°C; Ambient Temperature Range: -40°C to 85°C. Enclosure Type 4X & IP66
To be installed as per Moore Industries Field Installation Drawing 100-100-66.

APPLICABLE REQUIREMENTS

- CAN/CSA C22.2 No. 0-M1991 - General Requirements – Canadian Electrical Code Part II.
- 0.4-M1982 - Bonding and Grounding of Electrical Equipment (Protective Grounding)
- 25-1966 - Enclosures for use in Class II Groups E, F, and G Hazardous Locations.
- 94-M1991 - Special Purpose Enclosures
- 142-M1987 - Process Control Equipment
- 157-M1992 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations
- 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I Division 2 Hazardous Locations
- EN60529 : 1992 - Degree of protection provided by enclosures – IP Code (used as a guide)
- FM3600 - Electric Equipment for use in Hazardous (Classified) Locations. General Requirements
- FM3610 - Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, & III Division 1 and Class I, Zone 0 & 1 Hazardous (Classified) Locations.
- FM3611 - Nonincendive Electrical Equipment for Use in Class I and II Division 2 and Class III Divisions 1 and 2 Hazardous (Classified) Locations.

CONDITIONS OF ACCEPTABILITY

SPD-BL must have the optional backlight powered from an Intrinsic Safety Barrier. This circuit must enter the SPD enclosure via a separate conduit. A minimum spacing of 2mm must be maintained between all backlight circuits and the loop powered circuits.



Supplement to Certificate of Compliance

Certificate: 1361000 (LR 28549)

Master Contract: 152564

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1361000	March 20, 2003	Original Certification of Programmable Loop Display models SPD and SPD-BL.