



Certificate of Compliance

Certificate: 2223881

Master Contract: 152564

Project: 2223881

Date Issued: 2010/03/05

Issued to: **Moore Industries - International,
Inc.
16650 Schoenborn St
Sepulveda, CA 91343-6196
USA
Attention: Christine Whan**

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Ron Wachowicz, C.E.T.

Issued by: Ron Wachowicz, C.E.T.

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

Class I, Division 2, Groups A, B, C, D:

Programmable Safety Trip Alarm (STA), Din-rail mounting. Input rated 18-30Vdc, 3.5W max. or 90-260Vac, 4W max. Ambient -40°C to +85°C. Contacts rated 3A@250Vac 50/60 Hz or 3A@30Vdc. T-Code T4A.

Note: Electrical components must be mounted in a suitable enclosure.



Certificate: 2223881

Master Contract: 152564

Project: 2223881

Date Issued: 2010/03/05

APPLICABLE REQUIREMENTS

C22.2 No 0-M91 - General Requirements - Canadian Electrical Code Part II

C22.2 No 0.4-04 - Bonding of Electrical Equipment

C22.2 No 142-M1987 - Process Control Equipment

C22.2 No 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I Div 2 (HazLoc)

UL 508 - 17th Ed - Industrial Control Equipment

ANSI/ISA-12.12.01-2007 - Non-incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations Approved 06 April 2001



Supplement to Certificate of Compliance

Certificate: 2223881

Master Contract: 152564

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2223881	2010/03/05	New model certification for the Programmable Safety Trip Alarm (STA) model series suitable for Class I, Division 2, Groups A, B, C, D for C_US.