



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx FME 07.0003X issue No.:0 Certificate history:.....

Status: **Current**

Date of Issue: 2008-03-10 Page 1 of 5

Applicant: **Moore Industries International**  
16650 Schoeborn Street  
Noth Hills, CA 91343  
**United States of America**

Electrical Apparatus: **Model TFZ and Model TPZ Temperature Transmitters**  
Optional accessory:


Type of Protection: **Intrinsic Safety 'i' & Type "n" Electrical Apparatus**

Marking: **TFZ Temperature Transmitter**  
**Ex ia IIC T4 Ga Ta = -40°C to 85°C**  
**Ex nA nL IIC T4 Ta = -40°C to 85°C**  
**TPZ Temperature Transmitter**  
**Ex ia IIC T4 Ga Ta = -40°C to 85°C**  
**Ex nA IIC T4 Ta = -40°C to 85°C**

Approved for issue on behalf of the IECEx Certification Body: Andrew Was

Position: General Manager

Signature:  
(for printed version)

  
10<sup>TH</sup> March 2008

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

FM Approvals Ltd  
1 Windsor Dials  
SL4 1RS Windsor  
United Kingdom





# IECEX Certificate of Conformity

Certificate No.: IECEx FME 07.0003X

Date of Issue: 2008-03-10

Issue No.: 0

Page 2 of 5

Manufacturer: **Moore Industries International**  
16650 Schoeborn Street  
Noth Hills, CA 91343  
**United States of America**

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2004</b> Edition: 4.0	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
<b>IEC 60079-11 : 2006</b> Edition: 5	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-15 : 2005-03</b> Edition: Ed 3	Electrical apparatus for explosive gas atmospheres Part 15: Construction, test and Marking of Type of Protection "n" electrical apparatus
<b>IEC 60079-26 : 2006</b> Edition: 2	Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga
<b>IEC 60079-27 : 2005-04</b> Edition: 1.0	Electrical apparatus for explosive atmospheres- Part 27: Fieldbus intrinsically safe concept (FISCO) and Fieldbus non-incendive concept (FINCO)

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

[GB/FME/ExTR08.0001/00](#)

Quality Assessment Report:

[US/FMG/QAR07.0001/00](#)



# IECEx Certificate of Conformity

Certificate No.: IECEx FME 07.0003X

Date of Issue: 2008-03-10

Issue No.: 0

Page 3 of 5

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

#### **TFZ/a/H1/b/-c [d]. Temperature Transmitter.**

Energy Limitation Parameters:

Ui = 30Vdc, Ii = 300mA, Pi = 1.3W, Ci = 0μF, Li = 7.15μH.

FISCO Parameters:

Ui = 24Vdc, Ii = 380mA, Pi = 5.32W, Ci = 0μF, Li = 7.15μH.

Field Sensor Energy Limitation Parameters:

Uo = 6.51Vdc, Io = 34.75mA, Po = 55.97mW, Co = 20.53μF, Lo = 25mH (Group IIC)

Uo = 6.51Vdc, Io = 34.75mA, Po = 55.97mW, Co = 498.53μF, Lo = 100mH (Group IIB)

Uo = 6.51Vdc, Io = 34.75mA, Po = 55.97mW, Co = 998.53μF, Lo = 200mH (Group IIA).

a= Input: TPRG, J-, K-, E-, T-, R-, S-, N-, B-, C-, MV, R1-, R2-, R3-, R4-, R5-, R6-, R7-, R8, R9, R10-, R11-, R12-, R13-, R14-, RO- or POT-.

b= Power: 9-30Vdc (Intrinsically Safe), 9-24Vdc (FISCO).


c= Options: VTB or VTD.

d= Housing options: DN, FL, HP, TW or VDN.

### CONDITIONS OF CERTIFICATION: YES as shown below:

1. For Zone 0 installations the Model TPZ and TFZ Temperature Transmitters shall be installed in an enclosure which maintains an ingress protection rating of at least IP20.
2. For Zone 0 installations, the final enclosure shall not contain more than 10% in total of aluminum, magnesium, titanium and zirconium, or 7.5% in total of magnesium, titanium and zirconium; For Zone 1 installations, the final enclosure shall not contain 7.5% in total of magnesium.
3. Using the box provided on the nameplate, the user shall permanently mark the protection type chosen for the specific installation. Once the type of protection has been marked it shall not be changed.
4. The COM port shall not be used in the hazardous area.
5. If the Model TPZ and TFZ Temperature Transmitters are installed in Zone 2, they shall be installed in an enclosure which maintains an ingress protection rating of at least IP54 and meets the enclosure requirements of IEC 60079-0 and IEC 60079-15.

*Continued*



# IECEX Certificate of Conformity

Certificate No.: IECEx FME 07.0003X

Date of Issue: 2008-03-10

Issue No.: 0

Page 4 of 5

## EQUIPMENT(continued):

### **TFZ/a/H1/b/-c [d]. Temperature Transmitter.**

a= Input: TPRG, J-, K-, E-, T-, R-, S-, N-, B-, C-, MV, R1-, R2-, R3-, R4-, R5-, R6-, R7-, R8-, R9-, R10-, R11-, R12-, R13-, R14-, RO- or POT-.

b= Power: 9-32Vdc

c= Options: VTB or VTD.

d= Housing options: DN, FL, HP, TW or VDN.

### **TPZ/a/PA/b/-c [d]. Temperature Transmitter.**

Energy Limitation Parameters:

Ui = 30Vdc, Ii = 300mA, Pi = 1.3W, Ci = 0μF, Li = 7.15μH.

FISCO Parameters:

Ui = 24Vdc, Ii = 380mA, Pi = 5.32W, Ci = 0μF, Li = 7.15μH.

Field Sensor Energy Limitation Parameters:

Uo = 6.51Vdc, Io = 34.75mA, Po = 55.97mW, Co = 20.53μF, Lo = 25mH (Group IIC)

Uo = 6.51Vdc, Io = 34.75mA, Po = 55.97mW, Co = 498.53μF, Lo = 100mH (Group IIB)

Uo = 6.51Vdc, Io = 34.75mA, Po = 55.97mW, Co = 998.53μF, Lo = 200mH (Group IIA).

a= Input: TPRG, J-, K-, E-, T-, R-, S-, N-, B-, C-, MV, R1-, R2-, R3-, R4-, R5-, R6-, R7-, R8-, R9-, R10-, R11-, R12-, R13-, R14-, RO- or POT-.

b= Power: 9-30Vdc (Intrinsically Safe), 9-24Vdc (FISCO).

c= Options: VTB or VTD.

d= Housing options: DN, FL, HP, TW or VDN.

### **TPZ/a/PA/b/-c [d]. Temperature Transmitter.**

a= Input: TPRG, J-, K-, E-, T-, R-, S-, N-, B-, C-, MV, R1-, R2-, R3-, R4-, R5-, R6-, R7-, R8-, R9-, R10-, R11-, R12-, R13-, R14-, RO- or POT-.

b= Power: 9-32Vdc. (Type n)

c= Options: VTB or VTD.

d= Housing options: DN, FL, HP, TW or VDN.

