

1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

TRZ/PRG/4-20MA/12-28VDC/-ISA, ISC, ISCN, ISE, ISF, NE [LH2abc]. Temperature Transmitter.
XP/II/1/ABCD/T6 Ta = 60°C; DIP/II, III/1/EFG/T6 Ta = 60°C; Type 4X, IP66
a = Type of conduit entry/connection M (Metric M20 x 1.5) or N (1/2" NPT).
b = Standard black aluminum cover S.
c = Optional 2" Stainless steel pipe-mount hardware kit P.

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups B, C and D; dust ignitionproof for Class II/III, Division 1 Groups E F, and G, hazardous (classified) locations, indoors and outdoors rated NEMA Type 4X and IP66. The "TRZ" with "LH2" Instrument Housing is also rated as explosionproof for Class I, Division 1, Group A with 18 inches of conduit.

Approved for:

Moore Industries-International, Inc.
Sepulveda, CA 91343-6196

This certifies that the equipment described has been found to comply with the following Factory Mutual Research Approval Standards and other documents:

Class 3600	1989
Class 3615	1989
Class 3810	1989

Original Approval Job Identification: 2D6A0.AE Approval Granted: November 12, 1998

Subsequent Revision Reports / Date Approval Amended

3007838

May 23, 2000

Factory Mutual Research Corporation



P Stavrianidis
Assistant Vice President
Approvals Division

August 9, 2001
Date

An **FM** 610001 Affiliate