



DO NOT SCALE DRAWING

TOLERANCES (UNLESS NOTED)
 DECIMALS = ±incht/mm
 .X = ±.1 /2.54
 .XX = ±.03 /0.76
 .XXX = ±.010/0.25
 HOLES: ±.003-.002/+.08-.05
 ANGLES: = ± 30°

DRAWN	Gus H. Elias	09/00
CHECKED	C.B.	08/04
ENGINEER	Gus H. Elias	09/00
SCALE	NONE	

CONTROL DRAWING

TITLE Field Installation Diagram:
TRY & TRY-R [HPP]
 Isolated PC Prog. Temp. X-mitters.
 Intrinsically Safe System
 For Hazardous 'Classified' Locations.



DRAWING NUMBER
 100-100-49

REVISION	D		
APPROVAL	CB		
REVISOR	ECO 14104	DATE	BY
		G.E.	08/04

NOTICE RE PROPRIETARY INFORMATION: This drawing and the information contained herein are the proprietary property of Moore Industries-International, Inc. (MII) and should not be reproduced or disclosed to any third party without the written consent of an authorized officer of MII.

CERTIFIED PRODUCT
 This is a controlled 'Related' or 'Schedule' drawing. No modifications are permitted without the notification and final approval of the Certification Engineer (related dwgs.) or the Certifying Agency (schedule dwgs.).

Un-Classified (Non-Hazardous/Safe) Area



Entity Parameters (Power/Loop, +PS & -PS):

V_{max} or U_i	= 30 VDC
I_{max} or I_i	= 110 mA
P_{max} or P_i	= 0.825 W
C_i	= 10.34 nF
L_i	= 0 µH
C_a or C_o	$C_i + C_{cable}$
L_a or L_o	$L_i + L_{cable}$
V_{oc} or U_i	V_{oc} or V_t
I_{sc} or I_i	I_{sc} or I_t
P_i	P_o

Input device must be 'Agency' approved per application area (CSA, EECs, FM, ISSeP, KEMA LCIE, SIRA, SAA, TUV, etc...).

Hazardous (Classified) Locations - FM (US NEC 500) & CSA:
Intrinsically Safe: Class I,II,III; Div. 1; Groups A-G.
Non-Incendive: Class I, Div. 2, Groups A-D.
Class II, Div. 2, Groups F & G and Class III, Div. 2.
US NEC 505 (TRY-R only): Class I, Zone 0, AEx ia IIC
KEMA/CENELEC I.S. (TRY only): EEx ia IIC T4/T5
LCIE/ATEX I.S. (TRY-R): II 2G EEx ia IIC T6

T. Code: T6 @ 60°C Maximum Operating Ambient.
Temperature Range: -40°C Tamb. +60°C

Notes:

- Associated apparatus which is unspecified except that it **must not** be supplied from, or contain under normal or abnormal conditions a source of potential with respect to earth in excess of 250 VRMS or 250 VDC which is considered to be the Safe Area's maximum voltage.
- The Linear Output Associated Apparatus **must** be approved by the "specific" (CSA/EECS/FM/LCIE/SAA/SIRA/TUV, etc...) certifying agency for I.S. connections in "Class I-III, Division 1, Groups A-G" or "Zone 0" locations. The output voltage (**Voc, Vt or Vo**) **must not** exceed 30 VDC, the output current (**Isc, It or Io**) **must not** exceed 110 mA and, the output power (**Po**) must not exceed 0.825W (**Pi**). Also, it **must** be installed per the manufacturer's guidelines. *A Shunt Zener Barrier is NOT required for Non-Incendive (or Class I, Division 2 or Type N) installations.*
- The combined Capacitance and Inductance of the inter-connecting cables and the PC Prog. Transmitters **must not** exceed the values indicated on the Associated Apparatus.
- For FM applications, installation **must** be in accordance to "ANSI/ISA-RP12.06.01" (Installation of I.S. Systems for Hazardous 'Classified' Locations) and the National Electric Code 'ANSI/NFPA 70'. Also, a dust-tight conduit seal **must** be used when installed in Class II and Class III environments. For CSA applications, adhere to the 'Canadian Electric Code C22.1' most current publication on I.S. installation guidelines. For CENELEC/ATEX applications, adhere to 'EN 60079-14:1997' or any equivalent, most current and pertaining publication on I.S. installation guidelines.
- Warning:** Substitution of components may impair the unit's Intrinsic Safety & suitability for Class I, Division 2 areas. **DO NOT** open or service the unit when either energized or if an explosive gas/dust atmosphere is present. Disconnect power before servicing. Also read, understand and adhere to the manufacturer's installation and operating procedures.
- The maximum power parameters of the COM port (to be used only in safe/non-hazardous areas) are: $V_{max} = 3.0$ VDC, $I_{max} = 300$ µA, $P_{max} = 240$ µW.